GMLighting

BEFORE YOU START:

- Please check local electrical codes before beginning
- Consult with a licensed and qualified electrician or electrical contractor
- Turn power off before installing
- Make sure to use proper rated wire
- Do not install product in an environment outside the listed ambient temperature: -4F to 122F

FLUSH MOUNT INSTALLATION:

Install two screws (furnished) into junction box. Do not fully drive screws in. **(Fig. 1)**

Connect supply wires to wires in fixture wiring box using wire nuts (by others). Connect white to white, black to black, and green or bare copper wire to bare copper wire. (Fig. 2)

If there is a ground wire at junction box, secure it to ground screw.

Using a Phillips screwdriver, attach the disk light housing tightly to the junction box. (Fig. 3)

Press and twist the diffuser into housing, and twist to lock in place. **(Fig. 4)**

RETROFIT INSTALLATION FOR THE R-6


Install springs onto back of fixture housing using Phillips screwdriver. (Fig. 5)

Screw Retrofit E26 socket adapter into existing bulb receptacle. (Fig. 6)

Plug socket connector from disk light into socket connector from socket adapter. Install fixture by capturing springs in housing and firmly pushing up into ceiling (Fig. 7)

TOOLS NEEDED:

Phillips Screwdriver





©2021 GM Lighting Specifications are subject to change 18700 Ridgeland Ave. 150 Tinley Park, IL 60477 Toll-Free: (866) 671-0811 FAX: (708) 478-2640 www.gmlighting.net sales@gmlighting.net